## **ATTESTATION OF CONFORMITY**

Issued to: Zhejiang Chint Electrics Co., Ltd.

No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueging, 325603 Zhejiang,

China

For the product: Circuit-breaks incorporating residual current protection

Trade name: CHINT

Type/Model: NM8NL-125C, NM8NL-125S, NM8NL-125Q, NM8NL-125H and NM8NL-125R

Ratings: Ue: 380 Vac / 400 Vac / 415 Vac, 440 Vac, 50 / 60 Hz,

In: 16 A, 20 A, 25 A, 32 A, 40 A, 50 A, 63 A, 80 A, 100 A, 125 A

See annex for further ratings

Manufactured by: Zhejiang Chint Electrics Co., Ltd.

No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang,

China

Subject: Type test

Requirements: EN 60947-2:2017, EN 60947-5-1:2017, NEC 60947-2:2016 NEC 60947-5-1:2016

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a test report no. 3315345.50 issued on 2019-10-06, CQC CB test report no. 00901-CB2018CQC-084130 issued on 2019-03-25 with CB test certificate no. CN46412 and CQC CB test report no. 00901-CB2018CQC-084130-M1 issued on 2019-06-06 with CB test certificate no. CN46412-M1.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 11 October 2019 /// Number:/3315345.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo

Certification Manager

© Integral publication of this attestation and adjoining reports is allowed







Ratings

Number of poles 3P and 4P (unprotected N pole or protected N pole)

Protected poles 3 or 4

Rated operational voltage (Ue) 380 Vac / 400 Vac / 415 Vac, 440 Vac

Rated insulation voltage (Ui) 1000 V for main circuit

> 500 V for control circuit 500 V for auxiliary circuit 8 kV for main circuit

Rated impulse withstand voltage

(Uimp)

2,5 kV for shunt release and undervoltage release

6 kV for electric operating mechanism

2.5 kV for auxiliary circuit

Rated frequency 50 / 60 Hz

Rated current (In) 16 A, 20 A, 25 A, 32 A, 40 A, 50 A, 63 A, 80 A, 100 A, 125 A

Conventional thermal current (Ith) Equal to In Current rating for four-pole circuit-Equal to In

breakers

Individual pole short-circuit (I<sub>IT</sub>) 1,2 li at 440 Vac

Suitable for isolation Suitable

Selectivity category Α

Safety distance (screen-circuit Front / back: 0 mm breaker) Left / right: 0 mm

Up / down: 0 mm

40 °C Reference temperature Method of mounting fixed **EMC Environment** 

Tightening torque for terminals 6.0 Nm for M6 Line/load terminal **Immaterial** 

Connection copper conductor with cable lug Inverse time delay release Ir (inverse time delay tripping setting):

For thermal magnetic type: Ir: (0,7 / 0,8 / 0,9 / 1) x In

Time setting of the inverse time delay

release

Instantaneous release

Fixed, trip time at 2 ln:  $60 \text{ s} \le t \le 600 \text{ s}$ 

For thermal magnetic type:

li (instantaneous tripping setting):

li: 10 In

For electromagnetic type:

li: 12 ln

rated residual operating current (IΔn) For non-time-delay type:

Current setting:

Adjustable with fixed steps:

RCD1: 30 mA / 100 mA / 300 mA / 1000 mA, RCD2: 50 mA / 200 mA / 500 mA / 2000 mA

For time-delay type: Current setting:

Adjustable with fixed steps:

RCD1: 100 mA / 300 mA / 1000 mA, RCD2: 50 mA / 200 mA / 500 mA / 2000 mA Non-time-delay or adjustable time-delay:

time setting of rated residual

operating current

 $0.3 \, s / 0.5 \, s / 1.0 \, s$ : 0.06 s / 0.2 s / 0.5 s

the limiting non-actuating time at

 $2I\Delta n (\Delta t)$ 

Classification according to behaviour

in presence of a d.c. component

Type A or Type AC

Depedent on line voltage

Yes

Shunt release

SHT21-M8:

AC: 48 V, 110 V, 220 - 240 V, 380 - 415 V, 50 / 60 Hz





DC: 24 V, 48 V, 110 - 120 V, 220 V

Under-voltage release : UVT21-M8:

AC: 48 V, 110 V, 220 - 240 V, 380 - 415 V, 50 / 60 Hz

DC: 24 V, 48 V, 110 - 120 V, 220 V

Electric operating mechanism : MOD21-M8:

AC: 110 V, 220 - 240 V, 380 - 415 V, 50 / 60 Hz

DC: 24 V, 110 V, 220 V : AX21-M8 / AL21-M8

1 NO and 1 NC

AC-15: 2 A at 415 Vac, 4 A at 240 Vac,

5 A at 110 Vac

DC-13: 0,25 A at 220 Vdc / 110 Vdc

Ui: 500 V, Uimp: 2,5 kV

Rated conditional short-circuit current: 1 kA Fuse: RL6-25/6, 6 A, 500 Vac, 50 kA, Schneider

Product rating - NM8NL-125C

rated ultimate short-circuit breaking

capacity (Icu)

auxiliary circuits

rated service short-circuit breaking

capacity (Ics)

residual short-circuit making and

breaking capacity (I∆m)

: 36 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac,

: 36 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac,

: 9 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac,

Product rating - NM8NL-125S

rated ultimate short-circuit breaking

capacity (Icu)

rated service short-circuit breaking

capacity (lcs)

residual short-circuit making and

breaking capacity (I∆m)

: 50 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac,

: 50 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac,

: 12,5 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac,

Product rating - NM8NL-125Q

rated ultimate short-circuit breaking

capacity (Icu)

rated service short-circuit breaking

capacity (Ics)

residual short-circuit making and

breaking capacity (I∆m)

: 70 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac,

: 70 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac,

: 17,5 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac

Product rating - NM8NL-125H

rated ultimate short-circuit breaking

capacity (Icu)

rated service short-circuit breaking

capacity (Ics)

residual short-circuit making and

breaking capacity (IΔm)

: 100 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac,

: 100 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac.

25 kA at 380 Vac / 400 Vac / 415 Vac / 440 Vac

**Product rating - NM8NL-125R** 

rated ultimate short-circuit breaking

capacity (Icu)

rated service short-circuit breaking

capacity (Ics)

residual short-circuit making and

breaking capacity (I∆m)

: 150 kA at 380 Vac / 400 Vac / 415 Vac

100 kA at 440 Vac,

: 150 kA at 380 Vac / 400 Vac / 415 Vac

100 kA at 440 Vac.

: 37,5 kA at 380 Vac / 400 Vac / 415 Vac

25 kA at 440 Vac,



## Additional information

<u>NM8N L – 125 C TM 125 4</u>

a b c d e f g

a = model name: 'NM8N'

b = residual current protection device

c = frame size: '125'

d = short-circuit capacity: 'C', 'S', 'Q', 'H' or 'R'

e = trip unit: 'M' means electromagnetic type (ICB) or 'TM' means thermal magnetic type

f = rated current: 16 A, 20 A, 25 A, 32 A, 40 A, 50 A, 63 A, 80 A, 100 A, 125 A

g = number of poles: '4' means 4P, '3' means 3P

| Accessory type               | Model             |
|------------------------------|-------------------|
| Auxiliary circuit            | AX21-M8 / AL21-M8 |
| Shunt release                | SHT21-M8          |
| Undervoltage release         | UVT21-M8          |
| Electric operating mechanism | MOD21-M8          |
| Rotation handle              | DRH21-M8          |

