



Ref. Certif. No.

CN48107-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Moulded Case Circuit-breakers
Name and address of the applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the manufacturer	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the factory	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	See the Appendix
Trademark (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NM8N-400,NM8N-630,NM8NDC-400,NM8NDC-630;
Additional information (if necessary may also be reported on page 2)	
	IEC 60947-2:2016(5th Edition)
A sample of the product was tested and found to be in conformity with	
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2019CQC-086614-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jul.19,2020

Signature:

Lu Mei

CB 0056967

NM8N-400,NM8N-630,NM8NDC-400,NM8NDC-630

Uimp:12kV;

Ui:1000V;

Ue:AC380V/AC400V/AC415V,AC440V,AC500V,AC660V/AC690V,DC750V(3P in series),

DC1000V(4P in series);

In:

NM8N-400,NM8NDC-400:250A,315A,350A,400A(Thermo-magnetic, Electro-magnetic);

NM8N-630,NM8NDC-630:250A,315A,350A,400A,500A(Thermo-magnetic, Electro-magnetic);

250A,315A,350A,400A,500A,630A(Electronic);

Over-current release: Thermo-magnetic, Electro-magnetic, Electronic;

Ics=Icu:AC380V/AC400V/AC415V: 36kA/50kA/70kA/100kA/150kA(C/S/Q/H/R);

AC440V: 36kA/50kA/70kA/100kA/100kA(C/S/Q/H/R);

AC500V: 25kA/40kA/40kA/50kA/50kA(C/S/Q/H/R);

AC660V/AC690V: 10kA/12kA/12kA/15kA/15kA(C/S/Q/H/R);

DC750V(3P in series),DC1000V(4P in series): 25kA/36kA/50kA/70kA/100kA(B/C/S/Q/H);

Icw: Electronic:5kA 1s(In≤400A),8kA 1s(In≥500A);

Tripping class:5,10,20,30(ENM,EMM);

Selectivity category: A(Thermo-magnetic, Electro-magnetic),B(Electronic);

Pole:3P,4P;

Applicable for isolation;

50/60Hz;

Auxiliary contact and alarm contact:

Type:AX21-M8,AL21-M8(CB certificate:CN46412-M1);

1NO1NC;

Ith:5A;

AC-15:Ue/Ie:AC110V/5A,AC240V/4A,AC415V/2A;

DC-13:Ue/Ie:DC110V/0.25A,DC220V/0.25A;

Accessories with electronic circuits:

Undervoltage release:Type:UVT22-M8:

Us: AC48V, AC110V, AC220-240V, AC380-415V, 50/60Hz;

DC24V,DC48V,DC110V -120V,DC220V;


Page 1 of 2

Additional information (if necessary)

Date:

Jul.19,2020

Signature:



Lu Mei

Electric operator: Type:MOD23-M8:

Us: AC110V, AC220-240V, AC380-415V,50/60Hz; DC24V,DC110V,DC220V


Page 2 of 2

Additional information (if necessary)

Date:

Jul.19,2020

Signature:



Lu Mei