

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit-breakers

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NM8N-1600, NM8NDC-1600

Additional information (if necessary may also be
reported on page 2)

IEC 60947-2:2016(5th Edition)

A sample of the product was tested and found
to be in conformity withAs shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2019CQC-085133-M3


This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Jan.14,2021

Signature:



Lu Mei



NM8N-1600,NM8NDC-1600

Uimp:12kV

Ui:1000V

Ue:

AC380V/400V/415V, AC440V, AC500V, AC660/690V, DC1000V(Only NM8NDC-1600,4P),
DC750V(Only NM8NDC-1600,3P)

In:630A, 800A, 1000A, 1250A, 1600A(Maximum In for motor protective circuit-breaker:1250A)

Type of Over-current Release: Thermo-magnetic, Electronic

Thermo-magnetic:

Ics:

AC380V/400V/415V: 50kA/70kA/70kA(S/Q/H);

AC440V: 40kA/50kA/50kA(S/Q/H);

AC500V: 30kA/40kA/40kA(S/Q/H);

AC660V/690V: 30kA;

DC1000V: 25kA/36kA(B/C);

DC750V: 25kA/36kA(B/C);

Icu:

AC380V/400V/415V: 50kA/70kA/100kA(S/Q/H);

AC440V: 50kA/65kA/65kA(S/Q/H);

AC500V: 40kA/50kA/50kA(S/Q/H);

AC660V/690V: 30kA;

DC1000V: 25kA/36kA(B/C);

DC750V: 25kA/36kA(B/C);

Electronic:

Ics:

AC380V/400V/415V: 50kA/70kA/70kA(S/Q/H);

AC440V: 40kA/50kA/50kA(S/Q/H);

AC500V: 30kA/40kA/40kA(S/Q/H);

AC660V/690V: 30kA;

Page 1 of 2

Additional information (if necessary)

Date: Jan.14,2021

Signature:



Lu Mei

Icu:

AC380V/400V/415V: 50kA/70kA/100kA(S/Q/H);

AC440V: 50kA/65kA/65kA(S/Q/H);

AC500V: 40kA/50kA/50kA(S/Q/H);

AC660V/690V: 30kA;

Icw:20kA/1s(Electronic)

Selectivity category: A(Thermo-magnetic), B(Electronic)

3P, 4P(3 protected poles with a switched neutral pole)

Applicable for isolation

50/60Hz

Accessories with electronic circuits:

Shunt release: AC220/230V, AC380/400V

Undervoltage release:AC220/230V, AC380/400V

Auxiliary contacts and Alarm contacts: AX21-M8,AL21-M8

3NO3NC

Ith:5A ;

AC-15:Ue/Ie:AC110V/5A,AC240V/4A,AC415V/2A;

DC-13:Ue/Ie:DC110V/0.25A,DC220V/0.25A

Page 2 of 2

Additional information (if necessary)

Date:

Jan.14,2021

Signature:



Lu Mei