

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## **CB TEST CERTIFICATE**

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Moulded Case Circuit-breakers

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

NOARK Electrics (Shanghai) Co., Ltd.

No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

See the Appendix

**CHINT** 

N/A

NM8N-125, NM8NDC-125;

The latest CB certificate No. is CN55319-M1, dated 2023-04-24. The M2 certificate is to change parameters.

IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition)

00901-CB2021CQC-099512-M2

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86-10-83886666 Fax: +86-10-83886282

website: http://www.cqc.com.cn

Jun.28,2023

Date:







CN55319-M2

NM8N-125, NM8NDC-125

Uimp: 8kV; Ui: 1000V;

Ue: AC220/230/240V(1P), AC380/400/415V(2P, 3P, 4P), AC440V(2P, 3P, 4P), AC500V(2P, 3P, 4P), AC660/690V(2P, 3P, 4P), DC250V(1P appearance, 1P in series), DC500V(2P appearance, 2P in series), DC600V(3P appearance, 2P in series), DC750V(3P appearance, 3P in series), DC750V(4P appearance, 3P in series), DC800V(4P appearance, 3P in series), DC1000V(4P appearance, 4P in series);

In: 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A;

Over-current release: Thermo-magnetic, Electro-magnetic;

lcs=lcu: AC220/230/240V: 36/50kA(C/S); AC380/400/415V: 36/50/70/100/150kA(C/S/Q/H/R);

AC440V: 36/50/70/100/100kA(C/S/Q/H/R); AC500V: 25/40/40/50/50kA(C/S/Q/H/R); AC660/690V:

6/8/8/10/10kA(C/S/Q/H/R); DC250V(1P appearance, 1P in series): 25/36/50kA(B/C/S);

DC500V(2P appearance, 2P in series): 25/36/50/70/100kA(B/C/S/Q/H); DC750V(3P appearance,

3P in series), DC1000V(4P appearance, 4P in series): 25/36/50/70/100kA(B/C/S/Q/H);

DC600V(3P appearance, 2P in series): 50kA(WS); DC700V(3P appearance, 2P in series):

10kA(WS); DC750V(4P appearance, 3P in series): 70kA(WS); DC800V(4P appearance, 3P in

series): 50kA(WS);

Selectivity category: A;

Poles: 1P, 2P, 3P, 3P+N(3 protected poles with an uninterrupted pole), 4P(3 protected poles with a switched neutral pole), 4P, 2P appearance, 3P appearance, 4P appearance, see connection diagrams below;

Suitable for isolation;

Rated frequency: 50/60Hz;

Auxiliary contact and alarm contact(AX21-M8, AL21-M8, CB certificate: CN46412-M1):

1NO1NC;

Ith: 5A;

AC-15: Ue/le: AC110V/5A, AC240V/4A, AC415V/2A;

DC-13: Ue/le: DC110V/0.25A, DC220V/0.25A; Electronic accessories complied with Annex N:

Undervoltage release: UVT21-M8: Us: AC48V 50/60Hz, AC110V 50/60Hz, AC220~240V

Page 1 of 3

Additional information (if necessary)

Signature:


谢筆.则 Xie ZhaoXu




50/60Hz, AC380~415V 50/60Hz, DC24V, DC48V, DC110~120V, DC220V;

Electric operating mechanism: MOD21-M8: Us: AC110V 50/60Hz, AC220~240V 50/60Hz, AC380~415V 50/60Hz, DC24V, DC110V, DC220V;


Connection diagrams(All connections are applicable for upside or underside wiring.):




3P appearance, 3P in series



3P appearance, 2P in series



3P appearance, 3P in series (Make sure no secondary ground fault will happen to this installation)



4P appearance, 4P in series

Page 2 of 3

Additional information (if necessary)

Date:


Jun.28,2023

谢肇煦


Signature:

Xie ZhaoXu







4P appearance, 4P in series (Make sure no secondary ground fault will happen to this installation)



4P appearance, 4P in series (Make sure no secondary ground fault will happen to this installation)




2P appearance, 2P in series



2P appearance, 2P in series



1P appearance, 1P in series



4P appearance, 3P in series (Make sure no secondary ground fault will happen to this installation)

Page 3 of 3

Additional information (if necessary)

Date:

Jun.28,2023

新肇煦 Signature:

Xie ZhaoXu