

IEC**IECEE**

®

™

Ref. Certif. No.

CN64315

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

MCCB

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

*Note: When more than one factory, please report on page 2*Wenzhou CHINT Electrics Technology Co., Ltd.
No.1318, Binhai No.2 Avenue, Economic and Technical
Development Zone, Wenzhou City, Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NXMN-63;
NXMNP-63;NXMNF-63;NXMNH-63;NXMN-100;NXMNP-1
00; NXMNF-100; NXMNH-100;NXMN-125;
NXMNP-125;NXMNF-125; NXMNH-125;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition);IEC 60947-1:2007;IEC 60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

(2023)FQIIDQ-1041

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Dec.29,2023

Signature:

Xie ZhaoXu

NXMN-63; NXMNP-63;NXMNF-63;NXMNH-63;
 NXMN-100;NXMNP-100;NXMNF-100; NXMNH-100;
 NXMN-125; NXMNP-125;NXMNF-125; NXMNH-125;
 Uimp:8kV;Ui:800V;
 Ue: AC200V,AC220V/AC230V/AC240V,AC380V/AC400V/AC415V,AC660V/AC690V;
 Type of over-current release: Thermo-magnetic,electromagnetic;
 In:10A,15A,16A,20A,25A,30A,32A,40A,
 50A,60A,63A (NXMN□-63);
 In:10A,15A,16A,20A,25A,30A,32A,40A,
 50A,60A,63A,65A,70A,75A,80A,
 85A,90A,100A(NXMN□-100);
 In:10A,15A,16A,20A,25A,30A,32A,40A,
 50A,60A,63A,65A,70A,75A,80A,85A,90A,
 100A,110A,115A,120A,125A(NXMN□-125);
 Type C:(AC200V,AC380V/AC400V/AC415V)
 Ics=10kA,Icu=15kA;
 Type E:(AC200V,AC220V/AC230V/AC240V)/
 (AC380V/AC400V/AC415V);
 Ics=18kA/15kA,Icu=18kA/15kA;
 Type S:(AC200V,AC220V/AC230V/AC240V)/
 (AC380V/AC400V/AC415V)/
 (AC660V/AC690V);Ics=18kA/15kA/3kA,
 Icu=36kA/25kA/5kA;
 Type F: (AC200V,AC220V/AC230V/AC240V)/
 (AC380V/AC400V/AC415V)/
 (AC660V/AC690V);Ics=50kA/36kA/4kA,
 Icu=50kA/36kA/6kA;
 Type H:(AC200V,AC220V/AC230V/AC240V)/
 (AC380V/AC400V/AC415V)/
 (AC660V/AC690V);Ics=50kA/36kA/4kA,
 Icu=75kA/50kA/6kA;


Page 1 of 2

Additional information (if necessary)

Date:

Dec.29,2023

Signature:



Xie ZhaoXu

50Hz/60Hz; Selectivity category:A;
Trip class com.cqc.cms.component.word.CertiAnnexDataModel: 5,10A,10,20;
1P+N(1 protected poles with an uninterrupted neutral pole,Only Type C,
Type E,Type S),2P(Only Type C,Type E,Type S),3P,3P+N(3 protected poles with an
uninterrupted neutral pole),4P;
Suitable for isolation(Except 1P+N,3P+N);
Matching auxiliary contact:1NO+1NC;2NO+2NC;
Ui:500V;Ith:5A;
AC-15,Ue/Ie:AC380V/AC400V/AC415V/0.26A;
DC-13,Ue/Ie:DC110V,DC220V/DC250V/0.14A;
Electronic accessory complying with annex N:
Undervoltage release: AC110V,AC220V/AC230V/AC240V,
AC380V/AC400V/AC415V,DC24V,DC110V,DC220V/DC250V;
Motor-operator:AC110V,AC220V/AC230V/
AC240V,AC380V/AC400V/AC415V, DC24V,DC110V,DC220V/DC250V;
Shunt release with prepayment :
AC110V,AC220V/AC230V/AC240V,AC380V/
AC400V/AC415V,DC24V,DC110V,DC220V/DC250V.


Page 2 of 2

Additional information (if necessary)

Date:

Dec.29,2023

Signature:



Xie ZhaoXu