



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE230303008668

Product Moulded Case Circuit Breaker

Applicant Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model NXMN-63;
NXMNP-63;NXMNF-63;NXMNH-63;NXMN-100;NXMN
P-100; NXMNF-100; NXMNH-100;NXMN-125;
NXMNP-125;NXMNF-125; NXMNH-125;

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. (2023)FQIIDQCE-0341, the submitted sample(s) of the above item complies with:

EN 60947-2:2017/A1:2020;EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Dec.29,2023

Valid until: Dec.28,2026

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE230303008668

NXMN-63; NXMNP-63;NXMNF-63;NXMNH-63;
NXMN-100;NXMNP-100;NXMNF-100; NXMNH-100;
NXMN-125; NXMNP-125;NXMNF-125; NXMNH-125;
Uimp:8kV;Ui:800V;
Ue: AC200V,AC220V/AC230V/AC240V,
AC380V/AC400V/AC415V,AC660V/AC690V;
Type of over-current release: Thermo-magnetic,electromagnetic;
In:10A,15A,16A,20A,25A,30A,32A,40A,
50A,60A,63A (NXMN□-63);
In:10A,15A,16A,20A,25A,30A,32A,40A,
50A,60A,63A,65A,70A,75A,80A,
85A,90A,100A(NXMN□-100);
In:10A,15A,16A,20A,25A,30A,32A,40A,
50A,60A,63A,65A,70A,75A,80A,85A,90A,
100A,110A,115A,120A,125A(NXMN□-125);
Type C:(AC200V,AC380V/AC400V/AC415V)
Ics=10kA,Icu=15kA;
Type E:(AC200V,AC220V/AC230V/AC240V)/
(AC380V/AC400V/AC415V);
Ics=18kA/15kA,Icu=18kA/15kA;
Type S:(AC200V,AC220V/AC230V/AC240V)/
(AC380V/AC400V/AC415V)/
(AC660V/AC690V);Ics=18kA/15kA/3kA,
Icu=36kA/25kA/5kA;
Type F: (AC200V,AC220V/AC230V/AC240V)/
(AC380V/AC400V/AC415V)/
(AC660V/AC690V);Ics=50kA/36kA/4kA,



CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE230303008668

Icu=50kA/36kA/6kA;

Type H:(AC200V,AC220V/AC230V/AC240V)/
(AC380V/AC400V/AC415V)/

(AC660V/AC690V);Ics=50kA/36kA/4kA,

Icu=75kA/50kA/6kA;

50Hz/60Hz; Selectivity category:A;

Trip class com.cqc.cms.component.word.CertiAnnexDataModel: 5,10A,10,20;

1P+N(1 protected poles with an uninterrupted neutral pole,Only Type C,

Type E,Type S),2P(Only Type C,Type E,Type S),3P,3P+N(3 protected poles with an
uninterrupted neutral pole),4P;

Suitable for isolation(Except 1P+N,3P+N);

Matching auxiliary contact:1NO+1NC;2NO+2NC;

Ui:500V;lth:5A;

AC-15,Ue/Ie:AC380V/AC400V/AC415V/0.26A;

DC-13,Ue/Ie:DC110V,DC220V/DC250V/0.14A;

Electronic accessory complying with annex N:

Undervoltage release: AC110V,AC220V/AC230V/AC240V,
AC380V/AC400V/AC415V,DC24V,DC110V,DC220V/DC250V;

Motor-operator:AC110V,AC220V/AC230V/

AC240V,AC380V/AC400V/AC415V, DC24V,DC110V,DC220V/DC250V;

Shunt release with prepayment :

AC110V,AC220V/AC230V/AC240V,AC380V/

AC400V/AC415V,DC24V,DC110V,DC220V/DC250V.



CHINA QUALITY CERTIFICATION CENTRE