



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE240303008715

Product

Moulded Case Circuit Breaker

Applicant

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model

NXMN-W125C,E,S,F,H,R; NXMNH-W125C,E,S,F,H,R;
NXMNP-W125C,E,S,F,H,R; NXMNF-W125C,E,S,F,H,R;
NXMN-160C,E,S,F,H,R; NXMNH-160C,E,S,F,H,R;
NXMNP-160C,E,S,F,H,R; NXMNF-160C,E,S,F,H,R;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. (2023)FQIIDQCE-0348, the submitted sample(s) of the above item complies with:

EN 60947-2:2017/A1:2020;EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Feb.20,2024

Valid until: Feb.19,2027

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE240303008715

NXMN-W125C,E,S,F,H,R; NXMNH-W125C,E,S,F,H,R;
NXMNP-W125C,E,S,F,H,R; NXMNF-W125C,E,S,F,H,R;
NXMN-160C,E,S,F,H,R; NXMNH-160C,E,S,F,H,R;
NXMNP-160C,E,S,F,H,R; NXMNF-160C,E,S,F,H,R;
Uimp:8kV;Ui:800V;Ue: AC200V,AC220V/AC230V/AC240V,
AC380V/AC400V/AC415V,
AC660V/AC690V;
Type of over-current release: Thermo-magnetic,electromagnetic;
In:16A,20A,25A,30A,32A,40A,50A,60A,63A,65A,70A,75A,80A,85A,90A,100A,110A,
125A(NXMN□-W125);
In:16A,20A,25A,30A,32A,40A,50A,60A,63A,65A,70A,75A,80A,85A,90A,100A,110A,
125A,140A,150A,160A(NXMN□-160);
Type C:(AC200V,AC380V/
AC400V/AC415V) Ics=13kA,Icu=25kA;
Type E:(AC200V,AC220V/AC230V/
AC240V)/(AC380V/AC400V/AC415V)
(AC660V/AC690V);Ics=30kA/20kA/4kA,
Icu=40kA/20kA/8kA;
Type S:(AC200V,AC220V/AC230V/
AC240V)/(AC380V/AC400V/AC415V) (AC660V/AC690V);
Ics=30kA/20kA/4kA,Icu=50kA/36kA/8kA;
Type F:(AC200V,AC220V/AC230V/
AC240V)/(AC380V/AC400V/AC415V) (AC660V/AC690V);
Ics=50kA/36kA/5kA,Icu=50kA/36kA/10kA;
Type H:(AC200V,AC220V/AC230V/
AC240V)/(AC380V/AC400V/AC415V) (AC660V/AC690V)
Ics=50kA/36kA/5kA,Icu=75kA/50kA/10kA;



CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE240303008715

Type R:(AC200V,AC220V/AC230V/
AC240V)/(AC380V/AC400V/AC415V) (AC660V/AC690V)
Ics=50kA/50kA/5kA,Icu=75kA/70kA/10kA;
50Hz/60Hz; Selectivity category:A;
Trip class com.cqc.cms.component.word.CertiAnnexDataModel
com.cqc.cms.component.word.CertiAnnexDataModel
com.cqc.cms.component.word.CertiAnnexDataModel
com.cqc.cms.component.word.CertiAnnexDataModel:10A,10,20;
1P+N(1 protected poles with an uninterrupted neutral pole,Only Type C,
Type E,Type S),2P(Only Type C,Type E,Type S),3P,3P+N(3 protected poles with an
uninterrupted neutral pole),4P;
Suitable for isolation(Except 1P+N,3P+N);
Matching auxiliary contact:
1NO+1NC;2NO+2NC;
Ui:500V;lth:5A;
AC-15,Ue/Ie:AC380V/AC400V/AC415V/0.26A;
DC-13,Ue/Ie:DC110V,DC220V/DC250V/0.14A;
Electronic accessory complying with annex N:
Undervoltage release: AC110V,AC220V/AC230V/AC240V,
AC380V/AC400V/AC415V,DC24V,DC110V,DC220V/DC250V;
Motor-operator:AC110V,AC220V/AC230V/
AC240V,AC380V/AC400V/AC415V, DC24V,DC110V,DC220V/DC250V;
Shunt release with prepayment:
AC110V,AC220V/AC230V/AC240V,AC380V/AC400V/AC415V,
DC24V,DC110V,DC220V/DC250V.



CHINA QUALITY CERTIFICATION CENTRE