Ref. Certif. No.

CN75852

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Residual Current Operated Circuit Breaker
Name and address of the applicant	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Name and address of the manufacturer	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Name and address of the factory Note: *When more than one factory, please report on page 2*	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China
Ratings and principal characteristics	Uimp: 4kV;Ui: 500V;Ue: AC110V (2P), AC240V (2P), AC415V (4P);In: 16A, 25A, 40A, 63A; I∆ n: 30mA;type A; Electro-magnetic type;I∆ m: 500A (16A, 25A, 40A), 630A (63A); Im: 500A (16A, 25A, 40A), 630A (63A);2P, 4P
Trademark (if any)	NOARK
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	L1H;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 61008-2-1:1990(1st Edition);IEC 61008-1:2010, IEC 61008-1:2010/AMD1:2012, IEC 61008-1:2010/AMD2:2013
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2025CQC-125376

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Jan.04,2026

Signature: 谢肇煦
Xie ZhaoXu