CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
CERTIFICATE OF CONFORMITY

Certificate No.: CE250312009991

Product	Residual Current Operated Circuit Breaker
Applicant	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Type/Model	L1H
Technical data	Uimp: 4kV; Ui: 500V; Ue: AC110V (2P), AC240V (2P), AC415V (4P); In: 16A, 25A, 40A, 63A; IΔ n: 30mA; type A; Electro-magnetic type; IΔ m: 500A (16A, 25A, 40A), 630A (63A); Im: 500A (16A, 25A, 40A), 630A (63A); 2P, 4P

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2025CQC0312-016733, the submitted sample(s) of the above item complies with:

EN 61008-1:2012 + A1:2014+A2:2014+A11:2015+A12:2017 used in conjunction with EN 61008-2-1:1994 + A11:1998

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Jan.04,2026

Valid until: Jan.03,2029

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司 1101061026946