



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200303007048

Product

Moulded Case Circuit Breaker

Applicant

NOARK ELECTRIC USA INC.

2188 Pomona Blvd. Pomona, CA 91768-3322, USA

Type/Model

B1E

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2020CQC0303-011077, the submitted sample(s) of the above item complies with:

EN60947-2:2017

and fulfills testing requirements of the European Directive:

Low Voltage Directive (LVD): 2014/35/EU

Valid from: Dec.07,2020

Valid until: Dec.07,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0010960



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE200303007048

B1E
Uimp:6kV;
Ui:500V;
Ue:AC240V(1P),AC415V(2P,3P,4P),DC60V(1P appearance),DC125V(2P appearance);
In: 0.5A,1A,1.6A,2A,3A,4A,5A,6A,7A,8A,10A,13A,15A,16A,20A,25A,30A,
32A,35A,40A,45A,50A,60A,63A;
Over current release type: Thermal magnetic ;
Ics=7.5kA,Icu=10kA;
Applicable for isolation;
Rated frequency: 50/60Hz;
Selectivity category: A
1P,2P,3P,4P,1P appearance,2P appearance;
IP30 (Except for terminals);
Auxiliary contact and alarm contact:
1NO1NC
Ith: 6A;
AC-12: Ue/Ie: 480V/3A, 277V/3A, 240V/6A;
DC-12: Ue/Ie: 250V/0.5A, 125V/1A, 48V/2A, 24V/6A;
Electronic Accessories complied with Annex N;
Undervoltage release: UVT31;
Us:AC/DC48V, AC240V

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>