




Base Drawing




Technical Requirment

1. Static load: 4000kg (three pole); 1333kg (single pole);
   Dynamic load: Horizontal direction 22000N;
   Vertical direction (upward) 30000N,
   Vertical direction (down) 50000N.
2. The surface levelness of concrete is not greater than 1.5mm.


E (Terminals)




D-D (Anchor bolts)




G-G



Earth stud





For Reference Only

ALL DIMENSIONS IN MILLIMETRES

UNLESS OTHERWISE NOTED

Rev.	Date	Description	Designed	Checked	Approved

3RD ANGLE PROJECTION

LW43-252

CHINT ELECTRIC
Power Transmission & Distribution
3255 Sixian Road
Songjiang District 201614
Shanghai China
Tel: +86 21 6777 7777
Fax: +86 21 6777 7999

© COPYRIGHT CHINT ELECTRIC CO., LTD

Outline and Foundation Drawing of 252kV Circuit Breaker -monopolar

Designed		Scale		DRAWING NUMBER	Rev.
Checked		Page			1
Approved		Date			